


bsc

Air Change, Ventilation, and Dehumidification for Multi-family Buildings

Armin Rudd
Building Science Corp
www.buildingscience.com
for










MARCH 9-11, 2010
NESEA BUILDING ENERGY 40th ANNIVERSARY
BOSTON, MA


Acknowledgments:
USDOE Building America
Joseph Lstiburek, Peter Baker, Kohta Ueno--BSC

© 2010 Building Science Corporation

1








bsc

Reduce Individual Unit Stack Effect

- **Compartmentalization:** Isolation of individual apartment units from corridors and corridors from shafts, elevators and stairwells reduces stack effect driven interior airflows


© 2010 Building Science Corporation



bsc

- **Unit Air tightness:** Each unit is isolated from adjacent units and from the exterior by an air barrier system (minimum recommended resistance or air permeance of 2.00 L/(s.m2) @ 75 Pa is proposed). The inter-unit separation must also meet the specific fire resistance rating requirement for the given separation


© 2010 Building Science Corporation



bsc

- **Distributed Ventilation:**
- Individual unit ventilation provided across exterior walls, not across interior pressure boundaries such as floors and corridor walls


© 2010 Building Science Corporation



bsc


- **Gas Furnace Venting:** Sealed combustion furnaces (two pipe systems – exhaust gases out and combustion air in) are vented to roof or down to dry well ("pit" with screen). Vent runs can extend up or down up to 100 feet

© 2010 Building Science Corporation




Gas Water Heater Venting:
Sealed combustion domestic hot water heaters (two pipe systems – exhaust gases out and combustion air in) are vented to roof or down to dry well (“pit” with screen). Vent runs can extend up or down up 100 feet.

© 2010 Building Science Corporation




Air Conditioners or Heat Pump Configuration:
Individual units are located on roof or in drywell (“pit” covered with open structural grid/screen).

© 2010 Building Science Corporation



Mechanical Ventilation
Kitchen and bath fans controlled intermittently by occupant. Motorized damper in line with outside air duct connected to return side of air handler. Air handler fan and damper controlled to meet minimum duty cycle.

© 2010 Building Science Corporation



Heat Recovery Ventilator
Expensive to install, economical to operate

© 2010 Building Science Corporation



bsc



- Located in East Orange, NJ
- Five floors, retail space on the first floor, 56 residential units with 1000 - 1500 square feet of living area. There is a parking garage facility located below the first floor.
- Architect of record: Inglese Architecture and Engineering
- Constructed by RPM Development Group
- Design input, design and construction review, testing and modeling provided by BSC



© 2010 Building Science Corporation

bsc

© 2010 Building Science Corporation

bsc

- Unit-to-unit, and unit-to-corridor separation with floor-to-ceiling taped gypsum board and weather stripped doors


© 2010 Building Science Corporation



bsc



- Sealed combustion furnace and hot water heater piped to roof or basement pit


© 2010 Building Science Corporation



- Testing to quantify the air leakage characteristics of the dwelling units, corridors, and elevator shaft
- Normal operating pressure relationships between the living units, corridors, elevator shaft, stairwell, and outdoors were measured
- Then fan-forced air leakage testing on the stairwell, three corridors, seven living units on three different floors, and the elevator shaft with the coincident pressure response measured in the other zones
- Results were used to calculate air leakage metrics and to evaluate the effectiveness of air-sealing and compartmentalization of the building

© 2010 Building Science Corporation




Normal operating conditions


2 nd Floor		5 th Floor	
Unit	Unit pressure wrt corridor (Pa)	Unit	Unit pressure wrt corridor (Pa)
201	-0.4	501	-0.5
202	-0.3	502	-0.8
204	+0.8	503	-0.4
205	-0.7	504	-0.3
206	-0.8	505	0.0
207	-0.3	506	-0.1
208	-0.2	507	+1.1
209	+0.2	508	-0.5
210	+0.2	509	-0.3
211	+0.6	510	-0.2
212	+0.4	511	-0.5
213	+0.3	512	-0.8
214	0.0	513	-1.4

- Most of the values are negative
- In a traditional multi-story building, one would expect that stack effect would cause the lower floors to be negatively pressured and the upper floors to be positively pressured, which is not seen here due to effective compartmentalization

© 2010 Building Science Corporation




Depressurization of stairwell to outdoors




- The corridor, elevator, and living units do not respond to the changes in pressure of the stairwell, indicating that they are uncoupled from the stairwell. At -45 Pa the flow is about 2400 cfm

© 2010 Building Science Corporation







Depressurization of 2nd floor corridor into open stairwell




- Units 205 and 206 are more connected to the corridor than units 203 and 204 or the elevator shaft. Even so, all units are still more connected to outside than to the corridor.

© 2010 Building Science Corporation



bsc

**Stand-alone dehumidifier
installed in mechanical closet,
in central system return air path**




© 2010
Building Science
Corporation

APR 13 2001

bsc


**Stand-alone dehumidifier,
installed in conditioned space,
Ducted and integrated with central system**



© 2010
Building Science
Corporation

bsc

**DX cooling system with
modulating hot gas condenser reheat
providing dedicated dehumidification mode**



© 2010
Building Science
Corporation

bsc

Thank you!

© 2010
Building Science
Corporation





Table 11.1 Proposed Standard test conditions

	Outdoor T/RH/Tdp (F/%/F)	Indoor T/RH/Tdp (F/%/F)	
Test 1	95/58/78	80/60/65 78/55/61 75/50/55	cooling design conditions
Test 2	80/85/75	80/60/65 78/55/61 75/50/55	cooling part-load: summer nights/rainy periods
Test 3	75/85/70	78/60/63 78/55/61 75/50/55	cooling part-load: spring/fall
Test 4	65/90/62	72/60/57 70/52/52 68/45/46	no cooling: spring/fall/winter
Test 5 (opt)		65/55/49 ¹	cold climate basement conditions ¹ Single unit basement dehumidifier condition

© 2010 Building Science Corporation

39