

Supplemental Dehumidification For Humid Climates

ACI Conference, Denver, May 2, 2013

Armin Rudd



Overview of Results From

- BSC USDOE Building America field studies
- ASHRAE 1449-RP, simulation study, "Energy Efficiency and Cost Assessment of Humidity Control Options for Residential Buildings"

Supported By:

ASHRAE

AHRI

USDOE, Building America Program

Conducted By:

Building Science Corp

CDH Energy Corp

Armin Rudd

Hugh Henderson

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

2



What is Supplemental Dehumidification?

Moisture removal, supplemental to the cooling system, when there is no need for cooling.

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

3





When is it needed?

- Mostly when the house is floating between cooling and heating setpoints
- Spring/Fall swing seasons and summer shoulder months
- Some winter conditions in hot-humid climates
- Some summer nights and rainy periods in hot-humid climates and coastal warm-humid climates

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

4





What is a good metric for determining the need?

Hours above 60% relative humidity

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

1449-RP Conventional Cooling System


		Hours Above 60% RH	AC Runtime (hrs)	AC EER (Btu/W-h)	AC Energy (kWh)	Htg Energy (kWh)	AHU Fan Energy (kWh)	Exh Fan Energy (kWh)	Total Electric w/o HT (kWh)	Total Costs w Furnace (\$)
Orlando	HERS 50	1,011	3,286	21.3	1,863	633	140	203	2,311	\$ 265
	HERS 70	575	3,491	21.0	2,815	673	217	203	3,036	\$ 352
	HERS 85	1,123	2,039	16.8	3,911	2,247	700	203	4,511	\$ 614
	HERS 100	1,645	1,880	15.4	4,302	5,642	1,173	203	5,584	\$ 980
	HERS 130	1,361	2,127	11.7	6,623	6,876	1,368	203	8,190	\$ 1,352
Miami	HERS 50	822	4,378	21.0	2,516	38	173	203	2,833	\$ 296
	HERS 70	382	5,303	20.0	3,823	42	360	203	4,192	\$ 426
	HERS 85	796	2,859	16.5	5,064	420	347	203	6,214	\$ 857
	HERS 100	1,302	2,100	15.3	6,252	1,513	1,572	203	9,007	\$ 1,311
	HERS 130	1,312	3,054	11.8	9,506	1,344	1,786	203	11,495	\$ 1,509
Houston	HERS 50	395	3,242	20.4	1,963	1,788	181	203	2,347	\$ 263
	HERS 70	191	3,844	19.3	2,856	2,034	350	203	3,410	\$ 376
	HERS 85	228	2,186	16.3	3,876	3,047	750	203	4,838	\$ 540
	HERS 100	628	1,366	16.0	4,572	7,887	1,268	203	6,681	\$ 943
	HERS 130	342	2,170	11.4	6,923	14,361	1,555	203	8,581	\$ 1,388
Atlanta	HERS 50	40	2,054	21.1	1,148	3,070	135	203	1,488	\$ 161
	HERS 70	15	2,604	19.7	1,815	4,594	271	203	2,393	\$ 210
	HERS 85	20	1,703	16.6	2,364	6,228	515	203	3,082	\$ 338
	HERS 100	291	1,338	15.2	2,546	13,004	861	203	3,631	\$ 1,168
	HERS 130	426	1,726	11.7	3,533	16,387	335	203	4,668	\$ 1,573
Nashville	HERS 50	-	2,184	21.0	1,240	4,254	160	203	1,611	\$ 320
	HERS 70	-	2,611	19.7	1,853	5,375	289	203	2,341	\$ 475
	HERS 85	-	1,705	16.6	2,379	8,000	535	203	3,118	\$ 632
	HERS 100	4	1,565	15.4	2,938	10,150	908	203	4,083	\$ 823
	HERS 130	113	1,658	11.6	4,246	16,838	1,145	203	5,594	\$ 1,307
Indianapolis	HERS 50	-	1,457	21.5	812	8,823	198	203	1,213	\$ 364
	HERS 70	-	1,828	20.5	1,206	12,390	327	203	1,736	\$ 553
	HERS 85	-	1,134	17.0	1,952	13,605	463	203	2,239	\$ 634
	HERS 100	-	1,057	15.8	1,960	18,145	850	203	3,013	\$ 862
	HERS 130	7	1,240	12.0	3,050	22,302	1,029	203	4,322	\$ 1,177

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

1449-RP Conventional Cooling System

Table 1. Comparing Relative Annual Costs for each HERS Level and Climate

	HERS50	HERS70	HERS85	HERS100	HERS130	HERS130 No Vnt
Z0-Orlando	27%	36%	63%	100%	138%	129%
Z1-Miami	32%	46%	72%	100%	143%	134%
Z2-Houston	32%	44%	64%	100%	163%	154%
Z3-Atlanta	29%	44%	59%	100%	143%	135%
Z4-Nashville	39%	58%	77%	100%	169%	157%
Z5-Indianapolis	42%	64%	74%	100%	137%	126%



Conventional Cooling System Runtime 2-spd systems for HERS 70 and 50





Figure 1. Comparing Air Conditioner Runtime for Different Climates and HERS Levels

Hours > 60% RH by HERS Index and Climate Conventional Cooling System and Mechanical Ventilation



Duration of Events > 60% RH









Figure 1. Comparing Number of High Humidity Events (exceeding 60% RH) for Different Climates and HERS Levels




However, it has its limitations



- Mode 1: "normal cooling" 350 cfm/ton
- Mode 2: "cool to dehumidify" 280 cfm/ton only with a call for cooling
- Mode 3: "super dehumidify" 210 cfm/ton for 10 minutes on / 10 minutes off limited to 3°F overcooling

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

17



- Mode 1: "normal cooling" 350 cfm/ton
- Mode 2: "cool to dehumidify" 280 cfm/ton only with a call for cooling
- Mode 3: "super dehumidify" 210 cfm/ton for 10 minutes on / 10 minutes off limited to 3°F overcooling

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

18



How much supplemental dehumidification is needed?

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

19



Houston Field Study

Table 1. Monitoring results for Stand-alone dehumidifier system and the Ducted dehumidifier system in the Houston study

	Stand-alone Dehumidifier	Ducted Dehumidifier
Monitoring period	10/4/2001 - 7/31/2002	10/17/2001 - 8/1/2002
Total days with data	300	298
House dry bulb temperature (avg of 3 points)		
min	67	63
max	80	80
avg	73	72
std dev	2	3
House relative humidity (avg of 3 points)		
min	26	25
max	70	69
avg	50	51
std dev	8	7
House dew point temperature (avg of 3 points)		
min	35	32
max	64	66
avg	53	53
std dev	5	6
Hours above 60% RH	7%	4%
Supplemental dehumidification energy consumption (kWh)	209	463

Variation in occupant behaviors impacting internal generation has a big impact

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

20



Supplemental DH Results – HERS 85, 60% setpt

HERS 85, 60% RH Set Pt	Hours Above 61.5%	Hours Above 51.5%	Runtime (hrs)	AC EER (Btu/W-h)	AC Energy (kWh)	Htg Energy (kWh)	AHU Fan Energy (kWh)	DH Energy (kWh)	DH Fan Energy (kWh)	Total Electric w/o HT (kWh)	Total Costs w/ Furnace (\$)	
Orlando	S3 - 2-Spd	1,116	5,775	3,461	20.1	2,698	2,253	324	-	3,425	504	100%
	S2 - AC low flow	802	4,552	2,041	16.6	3,615	2,268	716	-	4,534	617	122%
	S8 - Partial SC/RH	507	4,467	2,072	16.4	3,633	2,285	723	-	4,613	627	124%
	SS - Full RH	1	4,117	2,124	16.5	3,717	2,229	825	-	4,745	641	127%
	S5 - DH Unit	127	4,551	2,046	16.6	3,627	2,169	843	183	4,862	643	126%
	S6 - Ducted DH	89	4,533	2,046	16.6	3,636	2,166	848	142	4,847	642	127%
S14 - Cond DES	-	4,357	2,039	16.6	3,614	2,229	847	145	4,822	645	126%	
Miami	S3 - 2-Spd	740	4,118	4,825	19.3	4,069	412	401	-	4,673	501	100%
	S2 - AC low flow	506	3,025	2,863	16.5	5,070	420	946	-	6,219	668	131%
	S8 - Partial SC/RH	182	2,360	2,892	16.3	6,150	421	953	-	6,306	667	133%
	SS - Full RH	2	2,799	2,923	16.4	5,148	427	1,052	-	6,443	681	136%
	S5 - DH Unit	83	3,148	2,865	16.5	5,077	349	1,039	131	6,451	676	135%
	S6 - Ducted DH	57	3,138	2,864	16.5	5,076	354	1,039	100	6,438	675	135%
S14 - Cond DES	-	2,398	2,856	16.5	5,061	376	1,038	107	6,425	675	135%	
Houston	S3 - 2-Spd	217	2,527	3,576	19.3	3,203	3,030	380	-	3,787	450	100%
	S2 - AC low flow	143	1,828	2,165	16.3	3,877	3,047	748	-	4,925	640	120%
	S8 - Partial SC/RH	55	1,727	2,195	16.2	3,501	3,059	761	-	4,865	543	121%
	SS - Full RH	-	1,598	2,214	16.3	3,917	3,060	868	-	4,988	554	123%
	S5 - DH Unit	35	1,858	2,183	16.3	3,876	3,052	882	47	5,009	565	123%
	S6 - Ducted DH	32	1,844	2,183	16.3	3,876	3,056	882	37	5,006	555	123%
S14 - Cond DES	-	1,780	2,181	16.3	3,873	3,063	882	37	5,001	555	123%	
Atlanta	S3 - 2-Spd	20	810	2,655	19.3	1,998	6,211	307	-	2,508	629	100%
	S2 - AC low flow	11	631	1,703	16.6	2,364	6,228	615	-	3,082	689	110%
	S8 - Partial SC/RH	11	631	1,703	16.6	2,364	6,228	615	-	3,082	689	110%
	SS - Full RH	5	618	1,715	16.8	2,379	6,229	583	-	3,165	697	111%
	S5 - DH Unit	-	530	1,695	16.6	2,354	6,289	670	-	3,227	707	113%
	S6 - Ducted DH	-	530	1,695	16.6	2,354	6,289	670	-	3,227	707	113%
S14 - Cond DES	-	530	1,695	16.6	2,354	6,289	670	-	3,227	707	113%	

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

Supplemental DH Results – HERS 85, 50% setpt


HERS 85, 50% RH Set Pt	Hours Above 61.5%	Hours Above 51.5%	Runtime (hrs)	AC EER (Btu/W-h)	AC Energy (kWh)	Htg Energy (kWh)	AHU Fan Energy (kWh)	DH Energy (kWh)	DH Fan Energy (kWh)	Total Electric w/o HT (kWh)	Total Costs w/ Furnace (\$)	
Orlando	S3 - 2-Spd	1,116	5,775	3,461	20.1	2,698	2,253	324	-	3,425	504	100%
	S2 - AC low flow	802	4,552	2,041	16.6	3,615	2,268	716	-	4,534	617	122%
	S8 - Partial SC/RH	507	4,467	2,072	16.4	3,633	2,285	723	-	4,613	627	124%
	SS - Full RH	1	4,117	2,124	16.5	3,717	2,229	825	-	4,745	641	127%
	S5 - DH Unit	127	4,551	2,046	16.6	3,627	2,169	843	183	4,862	643	126%
	S6 - Ducted DH	89	4,533	2,046	16.6	3,636	2,166	848	142	4,847	642	127%
S14 - Cond DES	-	4,357	2,039	16.6	3,614	2,229	847	145	4,822	645	126%	
Miami	S3 - 2-Spd	740	4,118	4,825	19.3	4,069	412	401	-	4,673	501	100%
	S2 - AC low flow	506	3,025	2,863	16.5	5,070	420	946	-	6,219	668	131%
	S8 - Partial SC/RH	182	2,360	2,892	16.3	6,150	421	953	-	6,306	667	133%
	SS - Full RH	2	2,799	2,923	16.4	5,148	427	1,052	-	6,443	681	136%
	S5 - DH Unit	83	3,148	2,865	16.5	5,077	349	1,039	131	6,451	676	135%
	S6 - Ducted DH	57	3,138	2,864	16.5	5,076	354	1,039	100	6,438	675	135%
S14 - Cond DES	-	2,398	2,856	16.5	5,061	376	1,038	107	6,425	675	135%	
Houston	S3 - 2-Spd	217	2,527	3,576	19.3	3,203	3,030	380	-	3,787	450	100%
	S2 - AC low flow	143	1,828	2,165	16.3	3,877	3,047	748	-	4,925	640	120%
	S8 - Partial SC/RH	55	1,727	2,195	16.2	3,501	3,059	761	-	4,865	543	121%
	SS - Full RH	-	1,598	2,214	16.3	3,917	3,060	868	-	4,988	554	123%
	S5 - DH Unit	35	1,858	2,183	16.3	3,876	3,052	882	47	5,009	565	123%
	S6 - Ducted DH	32	1,844	2,183	16.3	3,876	3,056	882	37	5,006	555	123%
S14 - Cond DES	-	1,780	2,181	16.3	3,873	3,063	882	37	5,001	555	123%	
Atlanta	S3 - 2-Spd	20	810	2,655	19.3	1,998	6,211	307	-	2,508	629	100%
	S2 - AC low flow	11	631	1,703	16.6	2,364	6,228	615	-	3,082	689	110%
	S8 - Partial SC/RH	11	631	1,703	16.6	2,364	6,228	615	-	3,082	689	110%
	SS - Full RH	5	618	1,715	16.8	2,379	6,229	583	-	3,165	697	111%
	S5 - DH Unit	-	530	1,695	16.6	2,354	6,289	670	-	3,227	707	113%
	S6 - Ducted DH	-	530	1,695	16.6	2,354	6,289	670	-	3,227	707	113%
S14 - Cond DES	-	530	1,695	16.6	2,354	6,289	670	-	3,227	707	113%	

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

Supplemental Dehumidification Energy and Cost

RH Setpoint	Dehumidification Energy over Com. System (kWh)	Product Ventilation					CFM Ventilation					ERV Ventilation				
		50%	60%	70%	80%	90%	50%	60%	70%	80%	90%	50%	60%	70%	80%	90%
		Cost over Com. System (\$)	Energy over Com. System (kWh)	Cost over Com. System (\$)	Energy over Com. System (kWh)	Cost over Com. System (\$)	Energy over Com. System (kWh)	Cost over Com. System (\$)	Energy over Com. System (kWh)	Cost over Com. System (\$)	Energy over Com. System (kWh)	Cost over Com. System (\$)	Energy over Com. System (kWh)	Cost over Com. System (\$)	Energy over Com. System (kWh)	Cost over Com. System (\$)
Orlando	Com or 2-spd	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Low flow overcool	19	3	127	19	17	3	106	17	8	1	102	19	10	109	109
	Subcool Reheat ¹	104	13	1019	110	141	16	943	102	139	16	1007	109	109	109	109
	Full Cond Reheat ²	230	27	888	79	232	29	954	68	227	29	854	77	77	77	77
	Standalone DH ³	247	39	1565	113	271	14	1316	105	216	13	1256	104	104	104	104
	Ducted DH ⁴	333	28	1448	125	203	12	1212	92	216	13	1256	104	104	104	104
Cond Desiccant ⁴	317	31	1332	122	184	16	1122	107	207	13	1256	104	104	104	104	
Miami	Com or 2-spd	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Low flow overcool	6	1	114	13	9	1	104	14	13	1	118	13	13	13	13
	Subcool Reheat ¹	93	9	879	90	136	15	855	89	177	20	1017	100	100	100	100
	Full Cond Reheat ²	230	24	892	61	242	26	916	55	255	28	890	64	64	64	64
	Standalone DH ³	239	19	1265	113	144	12	1064	98	200	16	1186	100	100	100	100
	Ducted DH ⁴	224	18	1103	102	154	11	968	89	188	16	1186	100	100	100	100
Cond Desiccant ⁴	212	18	956	94	141	12	869	84	188	16	1186	100	100	100	100	
Houston	Com or 2-spd	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Low flow overcool	8	0	4	4	4	0	48	4	4	0	48	4	4	4	4
	Subcool Reheat ¹	27	3	438	38	54	6	503	44	63	6	561	49	49	49	49
	Full Cond Reheat ²	150	13	334	30	163	14	338	30	162	14	365	33	33	33	33
	Standalone DH ³	171	15	676	54	87	4	588	45	76	5	647	48	48	48	48
	Ducted DH ⁴	189	15	622	50	60	3	537	41	61	3	647	48	48	48	48
Cond Desiccant ⁴	183	15	545	48	53	4	473	39	61	3	647	48	48	48	48	
Atlanta	Com or 2-spd	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	Low flow overcool	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Subcool Reheat ¹	0	0	103	11	0	0	107	11	0	0	84	8	8	8	8
	Full Cond Reheat ²	83	0	132	14	81	0	125	15	78	0	110	11	11	11	11
	Standalone DH ³	145	19	279	30	0	0	142	19	0	0	79	7	7	7	7
	Ducted DH ⁴	145	19	271	30	0	0	132	11	0	0	79	7	7	7	7
Cond Desiccant ⁴	145	19	252	29	0	0	120	12	0	0	79	7	7	7	7	

¹ This system does not control to a RH setpoint
² These systems will attempt to control to an RH setpoint but will not always meet the setpoint due to a limit on overcooling



Lessons Learned

- Periods of high relative humidity mostly occur at mild conditions in the winter and swing seasons when there is little or no need for sensible cooling. Humidity is rarely out of control during the main summer periods.
- The number of hours above a certain humidity threshold (say 60% RH) is good metric for comparing the humidity control performance of different systems. A similar result is found when analyzing the duration of high humidity events.
- Moving ducts from the attic to the conditioned space saves energy but increases space humidity levels in hot-humid climates. The reduction in sensible heat gains is greater than the reduction in latent loads, resulting in a mix of sensible and latent loads that increases space humidity levels in homes with conventional air conditioning systems.

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

26

U.S. DEPARTMENT OF ENERGY Energy Efficiency & Renewable Energy

DOE

DSC Building Science Corporation

Lessons Learned

- In a multi-home field study in Houston, TX, measured supplemental dehumidification energy consumption from two mechanically ventilated homes was 209 kWh/yr for a representative home with a stand-alone dehumidifier and 463 kWh/yr for another representative home with a ducted dehumidifier.
- The ducted dehumidifier was more efficient, and the homes had similar temperature and relative humidity control, but variability in occupant behaviors has a strong impact on internal moisture generation which has a strong impact on supplemental dehumidification requirements.

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

27

U.S. DEPARTMENT OF ENERGY Energy Efficiency & Renewable Energy

DOE

DSC Building Science Corporation

Lessons Learned (cont.)

- Detailed simulations showed that a number of humidity control solutions can be effective in hot-humid climates.
- The most effective solutions, having relatively low operating cost and essentially eliminating indoor humidity above 60% RH, were:
 - full condensing modulating reheat integrated with the central cooling system
 - ducted dehumidifier
 - stand-alone dehumidifier with central system mixing
 - condenser regenerated desiccant dehumidifier
- About 170 kWh/yr could be expected for a HERS 50 house (having ducts inside conditioned space) with a 60% RH setpoint.
- About five times that, and more, could be expected with a 50% RH setpoint.

ACI Conference – Supplemental Dehumidification
2 May 2013, Denver

28

U.S. DEPARTMENT OF ENERGY Energy Efficiency & Renewable Energy

DOE

DSC Building Science Corporation

Lessons Learned (cont.)

- A close second was central cooling system with subcooling reheat but it showed more elevated RH hours.
- A more distant third place was enhanced cooling controls for 2°F over-cooling and lower airflow (200 cfm/ton) activated at 50% RH and above.
- Two-speed and variable speed systems did little to reduce hours of elevated relative humidity in hot-humid climates unless coupled with the enhanced cooling methods listed above.
- An Energy Recovery Ventilators by itself increased hours above 60% RH in hot-humid climates, however, when coupled with supplemental dehumidification having a 50% RH setpoint an ERV reduced supplemental dehumidification energy needed

Lessons Learned (cont.)

- When controlling to 60% relative humidity, the required capacity for supplemental dehumidification in average homes in hot-humid climates is not large – about 1.5 lb/h, or that of a typical 40 to 50 pint/day unit.
- Expected cost to operate such a unit at 60% RH is less than \$50 yr depending on house efficiency level
- Expected cost to operate such a unit at 50% RH is less than \$175/yr depending on house efficiency level
- **Finally, supplemental dehumidification, in and of itself, does not save energy, rather, it is justified by enabling the energy savings from dramatically reduced sensible cooling loads in high-performance homes in hot-humid climates.**

Web Access to 1449-RP Results

RP1449

<http://cloud.cdhenenergy.com/rp1449/>

Location	HERS Rating	System Nr.	Relative Humidity	Vent Type
Orlando	HERS50	System 1	50% RH	No Vent
Miami	HERS51	System 2	60% RH	Exh Fan
Houston	HERS70	System 3		Exh 50%
Atlanta	HERS71	System 4		Exh 150%
Nashville	HERS85	System 4L		CFI
Indianapolis	HERS100	System 5		HRV
	HERS130	System 6		ERV

Set Criteria

- 2: Hours Above 60% RH
- 3: Hours Above 55% RH
- 4: Hours Above 50% RH
- 5: No of Events > 4 hrs
- 6: No of Events > 8 hrs
- 7: Space Temp Min (F)

Add Data Point

Save

(Saving Requires Login)

Table11_85_100_130 Load

Data Points Selected

None

Web Access to 1449-RP Results

<http://cloud.cdhenenergy.com/rp1449/>

Download Data

Location	HERS Rating	System Nr.	Relative Humidity	Vent Type	Hours Above 60% RH
Miami	HERS100	System 1	50% RH	Exh Fan	1303
Miami	HERS130	System 1	50% RH	Exh Fan	1313
Miami	HERS50	System 1	50% RH	Exh Fan	777
Miami	HERS70	System 1	50% RH	Exh Fan	433
Miami	HERS85	System 1	50% RH	Exh Fan	756

[View All PDFs](#)