

Joseph Lstiburek, Ph.D., P.Eng, ASHRAE Fellow

Building Science

Adventures In Building Science

www.buildingscience.com

Ventilation Rates Are Based on Odor Control

Building Science Corporation Joseph Lstiburek 2

Ventilation Rates Are Based on Odor Control Health Science Basis for Ventilation Rates is Extremely Limited


Building Science Corporation Joseph Lstiburek 3

Ventilation Rates Are Based on Odor Control Health Science Basis for Ventilation Rates is Extremely Limited Almost Nothing Cited Applies to Housing

Building Science Corporation Joseph Lstiburek 4

Ventilation Rates Are Based on Odor Control
 Health Science Basis for Ventilation Rates is
 Extremely Limited
 Almost Nothing Cited Applies to Housing
 The Applicable Studies Focus on Dampness

Building Science Corporation Joseph Lstiburek 5



House
 2,000 ft²
 3 bedrooms
 8 ft. ceiling
 Volume: 16,000 ft³

.35 ach	93 cfm
.30 ach	80 cfm
.25 ach	67 cfm
.20 ach	53 cfm
.15 ach	40 cfm

Building Science Corporation Joseph Lstiburek 7

House
 2,000 ft²
 3 bedrooms
 8 ft. ceiling
 Volume: 16,000 ft³


.35 ach	93 cfm	62 - 73	5 cfm/person	20 cfm
.30 ach	80 cfm		10 cfm/person	40 cfm
.25 ach	67 cfm	62 - 89	15 cfm/person	60 cfm
.20 ach	53 cfm		.35 ach	90 cfm
.15 ach	40 cfm	62.2 - 2010	7.5 cfm/person	50 cfm
			+ 0.01	
		62.2 - 2013	7.5 cfm/person	90 cfm
			+ 0.03	

Building Science Corporation Joseph Lstiburek 8

Office		
Occupant Density		
15/1000 ft ² (67 ft ² /person)	62 - 89	15 cfm/person
5/1000 ft ² (200 ft ² /person)	62.1 - 2007	17 cfm/person
Correctional Facility Cell		
Occupant Density		
20/1000 ft ² (48 ft ² /person)	62.1 - 2007	10 cfm/person

C.P. Yaglou	
Harvard School of Public Health	
1936	
1955	
150 ft ³	→ 20 cfm/person approx 4x4x8
300 ft ³	→ 12 cfm/person approx 6x6x8

C.P. Yaglou	
Harvard School of Public Health	
1936	
1955	
150 ft ³	→ 20 cfm/person 18.75 ft ² 106 occupants
300 ft ³	→ 12 cfm/person 37.5 ft ² 53 occupants
Experiment	
470 ft ³	→ 59 ft ²
200 ft ³	→ 25 ft ²
100 ft ³	→ 12 ft ²



Building Science Corporation

Joseph Lstiburek 12





Table 1. Summary of the air changes rates measured during the winter 2009-10 season in Quebec City

Method	ACH (h ⁻¹)	ACH standard deviation (h ⁻¹)	number of measurements
SF ₆ tracer decay	0.27	0.12	77
perfluorocarbon tracer	0.32	0.22	37
blower door at 50 Pa	4.16	2.64	63

Building Science Corporation Joseph Lstiburek 15

Build Tight - Ventilate Right

Building Science Corporation Joseph Lstiburek 16

Build Tight - Ventilate Right
How Tight?
What's Right?

Building Science Corporation

Joseph Lstiburek 17

Air Barrier Metrics

Material 0.02 l/(s-m²) @ 75 Pa
Assembly 0.20 l/(s-m²) @ 75 Pa
Enclosure 2.00 l/(s-m²) @ 75 Pa
0.35 cfm/ft² @ 50 Pa
0.25 cfm/ft² @ 50 Pa
0.15 cfm/ft² @ 50 Pa

Building Science Corporation

Joseph Lstiburek 18

Getting rid of big holes 3 ach@50
Getting rid of smaller holes 1.5 ach@50
Getting German 0.6 ach@50

Building Science Corporation

Joseph Lstiburek 19

Best

As Tight as Possible - with -
Balanced Ventilation
Energy Recovery
Distribution and Mixing
Source Control - Spot exhaust ventilation
Filtration
Material selection




Building Science Corporation



Joseph Lstiburek 20

Worst

Leaky - with – Nothing
Spot Ventilation in Bathroom/Kitchen
Exhaust Ventilation – with – No Distribution
and No Mixing

Building Science Corporation
Joseph Lstiburek 21





Cost	Exhaust	\$150
	Exhaust + Dist + Mix	\$200
	Supply + Dist + Mix	\$200
	Spot + Ex/Sup + Dist + Mix	\$500
	Balanced/HRV	\$1,250

The diagram is labeled 'Building Science Corporation' and 'Joseph Lstiburek 27'.

ASHRAE Standard 62.2 calls for 7.5 cfm per person plus 0.03 cfm per square foot of conditioned area
 Occupancy is deemed to be the number of bedrooms plus one

The diagram is labeled 'Building Science Corporation' and 'Joseph Lstiburek 28'.

ASHRAE Standard 62.2 calls for 7.5 cfm per person plus 0.03 cfm per square foot of conditioned area

Occupancy is deemed to be the number of bedrooms plus one

Outcome is often bad – part load humidity problems, dryness problems, energy problems

Building Science Corporation

Joseph Lstiburek 29

The Cult of The Blower Door


Building Science Corporation

Joseph Lstiburek 30




Building Science Corporation

Joseph Lstiburek 31



Building Science Corporation

Joseph Lstiburek 32




Blower Door Can't Get You The True ACH
On A Short Term Basis – Hour, Day, Week


Building Science Corporation
Joseph Lstiburek 34

Don't Know Where The Holes Are
Don't Know The Type of Holes
Don't Know The Pressure Across The Holes

Building Science Corporation
Joseph Lstiburek 35



Recommended Range of Relative Humidity
 Above 25 percent during winter
 Below 70 percent during summer



Barriers – Technology Dehumidification

Barriers – Cost

- Exhaust \$150
- Exhaust + Dist \$200
- Supply + Dist \$200
- Spot + Ex/Sup + Dist \$500
- Balanced/ER \$1,250
- Dehumidification \$250 to \$1,250



Tracer Gas Testing
January 2006

- Tracer gas test of a production house in Sacramento
- 2-story, 4 bedrooms, ~2500 square feet
- Ventilation systems tested: supply and exhaust ventilation, with and without mixing via central air handler

Building Science Corporation Joseph Lstiburek 41



Floor Plan - 2 Story House









1ST FLOOR

2ND FLOOR

Building Science Corporation Joseph Lstiburek 42







$Q(v)$ = Ventilation Rate
 $Q(fan) = Q(v) \cdot C(s)$
 $C(s)$ = System Coefficient

Building Science Corporation Joseph Lstiburek 51

Airflow Ratios—All Simulations

System Type	Range	Approximate Median
Fully ducted balanced ventilation system, with or without central duct system	1.0	1.0
Non-fully ducted balanced ventilation, with central duct system, and central air handler unit controlled to a minimum runtime of at least 10 minutes per hour	0.9 to 1.1	1.0
Supply ventilation, with central duct system, and central air handler unit controlled to a minimum runtime of at least 10 minutes per hour	1.1 to 1.7	1.25
Exhaust ventilation, with central duct system, and central air handler unit controlled to a minimum runtime of at least 10 minutes per hour	1.1 to 1.9	1.25
Exhaust ventilation, with central duct system, and central air handler unit not controlled to a minimum runtime of at least 10 minutes per hour	1.0 to 1.8	1.5
Supply ventilation, without central duct system	1.4 to 1.9	1.75
Exhaust ventilation, without central duct system	1.3 to 2.6	2.0

Building Science Corporation Joseph Lstiburek 52

BSC 01 - 2013 calls for 7.5 cfm per person
plus 0.01 cfm per square foot of
conditioned area

Occupancy is deemed to be the number of
bedrooms plus one

Occupant Rate + Building Rate

$Q(v)$ = Fan Flow Rate

$Q(\text{fan}) = Q(v) \cdot C(d)$

$C(s)$ = System Coefficient

Table 4.1

System Coefficient based on system type¹

System Type	Distributed	Not Distributed
Balanced	1.0	1.25
Not Balanced	1.25	1.5

¹ Where there is whole-building air mixing of at least 70% recirculation turnover each hour, the system coefficient may be reduced by 0.25.

BSC 01-2013

Ventilation for New Low-Rise Residential Building

2,000 ft²

3 bedrooms

20 cfm + 30 cfm = 50 cfm

Mixed, Distributed, Balanced (MDB)

37.5 cfm

Not Mixed, Not Distributed, Not Balanced

75 cfm

House			
2,000 ft ²			
3 bedrooms			
8 ft. ceiling			
Volume: 16,000 ft ³			
Ventilation Rates			
.35 ach	93 cfm	62 - 73	5 cfm/person 20 cfm
.30 ach	80 cfm		10 cfm/person 40 cfm
.25 ach	67 cfm	62 - 89	15 cfm/person 60 cfm
.20 ach	53 cfm		.35 ach 90 cfm
.15 ach	40 cfm	62.2 - 2010	7.5 cfm/person 50 cfm
			+ 0.01
		62.2 - 2013	7.5 cfm/person 90 cfm
			+ 0.03
		BSC 01 - 2013	7.5 cfm/person 37 cfm
			+ 0.01 (MBD) 75 cfm

Building Science Corporation

Joseph Lstiburek 57