


Joseph Lstiburek, Ph.D., P.Eng, ASHRAE Fellow




Building Science


Adventures In Building Science

www.buildingscience.com

























Duct Leakage Should Be Less Than 5% of Rated Flow As Tested by Pressurization To 25 Pascals

Building Science Corporation Joseph Lstiburek 33



Building Science Corporation Joseph Lstiburek 34






Air handling unit




Note: Colored shading depicts the building's thermal barrier and pressure boundary. The thermal barrier and pressure boundary enclose the conditioned space.



Building Science Corporation Joseph Lstiburek 35








Building Science Corporation Joseph Lstiburek 36


































Building Science Corporation

Joseph Lstiburek 77



Building Science Corporation

Joseph Lstiburek 78

Ventilation Rates Are Based on Odor Control

Building Science Corporation

Joseph Lstiburek 79

Ventilation Rates Are Based on Odor Control
Health Science Basis for Ventilation Rates is Extremely Limited

Building Science Corporation



Joseph Lstiburek 80

Ventilation Rates Are Based on Odor Control
 Health Science Basis for Ventilation Rates is
 Extremely Limited
 Almost Nothing Cited Applies to Housing

Building Science Corporation Joseph Lstiburek 81

Ventilation Rates Are Based on Odor Control
 Health Science Basis for Ventilation Rates is
 Extremely Limited
 Almost Nothing Cited Applies to Housing
 The Applicable Studies Focus on Dampness

Building Science Corporation Joseph Lstiburek 82



House
 2,000 ft²
 3 bedrooms
 8 ft. ceiling
 Volume: 16,000 ft³

.35 ach	93 cfm
.30 ach	80 cfm
.25 ach	67 cfm
.20 ach	53 cfm
.15 ach	40 cfm

Building Science Corporation Joseph Lstiburek 85

House
 2,000 ft²
 3 bedrooms
 8 ft. ceiling
 Volume: 16,000 ft³

.35 ach	93 cfm	62 - 73	5 cfm/person	20 cfm
.30 ach	80 cfm		10 cfm/person	40 cfm
.25 ach	67 cfm	62 - 89	15 cfm/person	60 cfm
.20 ach	53 cfm		.35 ach	90 cfm
.15 ach	40 cfm	62.2 - 2010	7.5 cfm/person	50 cfm
			+ 0.01	
		62.2 - 2013	7.5 cfm/person	90 cfm
			+ 0.03	

Building Science Corporation Joseph Lstiburek 86

Office
Occupant Density

15/1000 ft ² (67 ft ² /person)	62 - 89
15 cfm/person	
5/1000 ft ² (200 ft ² /person)	62.1 - 2007
17 cfm/person	

Correctional Facility Cell
Occupant Density

20/1000 ft ² (48 ft ² /person)	62.1 - 2007
10 cfm/person	

C.P. Yaglou
Harvard School of Public Health
 1936
 1955

150 ft ³	→	20 cfm/person
300 ft ³	→	12 cfm/person

C.P. Yaglou
 Harvard School of Public Health
 1936
 1955

150 ft³ → 20 cfm/person 18.75 ft² 106 occupants
 300 ft³ → 12 cfm/person 37.5 ft² 53 occupants

Experiment

470 ft³ → 59 ft²
 200 ft³ → 25 ft²
 100 ft³ → 12 ft²






Table 1. Summary of the air changes rates measured during the winter 2009-10 season in Quebec City

Method	ACH (h ⁻¹)	ACH standard deviation (h ⁻¹)	number of measurements
SF ₆ tracer decay	0.27	0.12	77
perfluorocarbon tracer	0.32	0.22	37
blower door at 50 Pa	4.16	2.64	63

Building Science Corporation Joseph Lstiburek 93

Build Tight - Ventilate Right

Building Science Corporation Joseph Lstiburek 94

Build Tight - Ventilate Right

How Tight?
What's Right?

Building Science Corporation Joseph Lstiburek 95

Air Barrier Metrics

Material 0.02 l/(s-m2) @ 75 Pa
 Assembly 0.20 l/(s-m2) @ 75 Pa
 Enclosure 2.00 l/(s-m2) @ 75 Pa
 0.35 cfm/ft2 @ 50 Pa
 0.25 cfm/ft2 @ 50 Pa
 0.15 cfm/ft2 @ 50 Pa

Building Science Corporation Joseph Lstiburek 96

Getting rid of big holes 3 ach@50
 Getting rid of smaller holes 1.5 ach@50
 Getting German 0.6 ach@50

Building Science Corporation Joseph Lstiburek 97

Best


As Tight as Possible - with -
 Balanced Ventilation
 Energy Recovery
 Distribution and Mixing
 Source Control - Spot exhaust ventilation
 Filtration
 Material selection





Building Science Corporation Joseph Lstiburek 98

Worst

Leaky - with – Nothing
 Spot Ventilation in Bathroom/Kitchen
 Exhaust Ventilation – with – No Distribution
 and No Mixing

Building Science Corporation Joseph Lstiburek 99





Cost	Exhaust	\$150
	Exhaust + Dist + Mix	\$200
	Supply + Dist + Mix	\$200
	Spot + Ex/Sup + Dist + Mix	\$500
	Balanced/HRV	\$1,250

ASHRAE Standard 62.2 calls for 7.5 cfm per person plus 0.03 cfm per square foot of conditioned area


Occupancy is deemed to be the number of bedrooms plus one

ASHRAE Standard 62.2 calls for 7.5 cfm per person plus 0.03 cfm per square foot of conditioned area

Occupancy is deemed to be the number of bedrooms plus one

Outcome is often bad – part load humidity problems, dryness problems, energy problems

The Cult of The Blower Door



Building Science Corporation

Joseph Lstiburek 109

Blower Door Can't Get You The True ACH
On A Short Term Basis – Hour, Day, Week


Building Science Corporation

Joseph Lstiburek 110

Don't Know Where The Holes Are
Don't Know The Type of Holes
Don't Know The Pressure Across The Holes

Building Science Corporation


Joseph Lstiburek 111



Building Science Corporation

Joseph Lstiburek 112

Recommended Range of Relative Humidity
 Above 25 percent during winter
 Below 70 percent during summer



Barriers – Technology Dehumidification

Barriers – Cost	Exhaust \$150
	Exhaust + Dist \$200
	Supply + Dist \$200
	Spot + Ex/Sup + Dist \$500
	Balanced/ER \$1,250
	Dehumidification \$250 to \$1,250

Building Science Corporation
 Joseph Lstiburek 116



Tracer Gas Testing
January 2006

- Tracer gas test of a production house in Sacramento
- 2-story, 4 bedrooms, ~2500 square feet
- Ventilation systems tested: supply and exhaust ventilation, with and without mixing via central air handler

Building Science Corporation Joseph Lstiburek 117



Floor Plan - 2 Story House









1ST FLOOR: FAMILY, BREAKFAST, KITCHEN, DINING, LIVING, ENTRY, GARAGE, PORCH, BEDROOM, BATH.

2ND FLOOR: BEDROOM, HALL, M. BEDROOM, W.C., BEDROOM, BATH, OPEN TO BELOW.

Building Science Corporation Joseph Lstiburek 118







Tuned CONTAM Model Applied to Other Systems

Systems Evaluated & Compared:

1. Exhaust ventilation, without central duct system
2. Supply ventilation, without central duct system
3. Exhaust ventilation, with central ducts, standard Tstat
4. Exhaust ventilation, with central ducts, Tstat with timer
5. Supply ventilation, with central ducts, Tstat with timer
6. Fully ducted balanced ventilation system, without central duct system

Building Science Corporation Joseph Lstiburek 127

$Q(v)$ = Ventilation Rate

$Q(\text{fan}) = Q(v) \cdot C(s)$

$C(s)$ = System Coefficient

Building Science Corporation Joseph Lstiburek 128

Airflow Ratios—All Simulations

System Type	Range	Approximate Median
Fully ducted balanced ventilation system, with or without central duct system	1.0	1.0
Non-fully ducted balanced ventilation, with central duct system, and central air handler unit controlled to a minimum runtime of at least 10 minutes per hour	0.9 to 1.1	1.0
Supply ventilation, with central duct system, and central air handler unit controlled to a minimum runtime of at least 10 minutes per hour	1.1 to 1.7	1.25
Exhaust ventilation, with central duct system, and central air handler unit controlled to a minimum runtime of at least 10 minutes per hour	1.1 to 1.9	1.25
Exhaust ventilation, with central duct system, and central air handler unit not controlled to a minimum runtime of at least 10 minutes per hour	1.0 to 1.8	1.5
Supply ventilation, without central duct system	1.4 to 1.9	1.75
Exhaust ventilation, without central duct system	1.3 to 2.6	2.0

BSC 01 - 2013 calls for 7.5 cfm per person plus 0.01 cfm per square foot of conditioned area

Occupancy is deemed to be the number of bedrooms plus one

Occupant Rate + Building Rate

$Q(v)$ = Fan Flow Rate

$Q(fan)$ = $Q(v) \cdot C(d)$

$C(s)$ = System Coefficient

Table 4.1

System Coefficient based on system type¹

System Type	Distributed	Not Distributed
Balanced	1.0	1.25
Not Balanced	1.25	1.5

¹ Where there is whole-building air mixing of at least 70% recirculation turnover each hour, the system coefficient may be reduced by 0.25.

BSC 01-2013
Ventilation for New Low-Rise Residential Building
 2,000 ft²
 3 bedrooms

20 cfm + 30 cfm = 50 cfm

Mixed, Distributed, Balanced (MDB)
 37.5 cfm

Not Mixed, Not Distributed, Not Balanced
 75 cfm

House
 2,000 ft²
 3 bedrooms
 8 ft. ceiling
 Volume: 16,000 ft³

		Ventilation Rates	
.35 ach	93 cfm	62 - 73	5 cfm/person 20 cfm
.30 ach	80 cfm		10 cfm/person 40 cfm
.25 ach	67 cfm	62 - 89	15 cfm/person 60 cfm
.20 ach	53 cfm		.35 ach 90 cfm
.15 ach	40 cfm	62.2 - 2010	7.5 cfm/person 50 cfm
			+ 0.01
		62.2 - 2013	7.5 cfm/person 90 cfm
			+ 0.03
		BSC 01 - 2013	7.5 cfm/person 37 cfm
			+ 0.01 (MBD) 75 cfm

Building Science Corporation Joseph Lstiburek 134

Building Science Corporation Joseph Lstiburek 135