


U.S. Department of Energy  
**Energy Efficiency and Renewable Energy**  
Bringing you a program that makes energy  
is clean, abundant, reliable, and affordable  
Building Technologies Program



## Residential Heating and Cooling Loads

By:  
Armin Rudd  
Building Science Corp.  
[www.buildingscience.com](http://www.buildingscience.com)


For:  
Affordable Comfort Conference  
Kansas City  
28 April 2009

Building Science Consortium

## OVERVIEW

- Brief systems engineering introduction
- Discussion of heating and cooling loads by way of examining the system sizing process.

Building Science Consortium



## SYSTEM ENGINEERING TRADE-OFFS

- **Better Envelopes**
  - Allow for reduced cooling system size
  - Decrease energy consumption
  - Increase occupant comfort
  - Make overall performance more predictable
  - Improve the more permanent features of a home which has longer-term sustainability benefits to society

Building Science Consortium

### SYSTEM ENGINEERING TRADE-OFFS

- **Reduced cooling system size**
  - Helps pay for a better envelope
  - Avoids cooling system short-cycling
    - which improves moisture removal
    - allows the system to operate at higher average efficiency

Building Science Consortium

### SYSTEM ENGINEERING TRADE-OFFS

- **More efficient systems**
  - Are most cost effective when the load is high
    - this is in circular conflict with our premise to first reduce loads through improved envelopes
  - High efficiency cooling systems generally have a higher evaporator coil temperature which reduces moisture removal
    - some of this can be altered with effective control of ECM air handlers

Building Science Consortium

**High performance building envelopes deserve high performance comfort conditioning systems.**

**Especially for refrigerant based cooling systems, proper sizing and startup procedures are critical.**

Building Science Consortium

### Do this before you start

- **Builder must commit to these**
  1. Building enclosure leakage  $\leq 0.35$  cfm50/ft<sup>2</sup> enclosure surface area
  2. Ducts inside conditioned space. or duct leakage  $\leq 5\%$  to outside
  3. Glazing U-value and SHGC  $\leq 0.35$
  4. Proper return air provision to assure  $< 3$  Pa pressure differential between rooms to common area

Building Science Consortium

## Room Transfer Air

Room supply cfm	Transfer grille height required for listed width in inches			Jump Duct Diameter (in)
	10 (in)	12 (in)	14 (in)	
<=100	6	6	4	8
>100 and <=125	8	6	6	8
>125 and <=150	10	8	8	10
>150 and <=175	12	10	8	10
>175 and <=225	14	12	10	12

Building Science Consortium

## SYSTEM SIZING SPECIFICATION

- 1. Computer software adhering to ACCA Manual J version 8 will be used to calculate loads for cooling and heating systems.
  - RHVAC from Elite Software ([www.elitesoft.com](http://www.elitesoft.com))
  - Right-J from Wrightsoft ([www.wrightsoft.com](http://www.wrightsoft.com))

Building Science Consortium

## SYSTEM SIZING SPECIFICATION

- 2. Duct gain and loss:
  - Best to locate entire air distribution system inside conditioned space, duct gain and loss=zero
  - If not in conditioned space, then air seal with mastic, insulate to R-8 with metalized insulation wrap;
  - Duct gain and loss will be calculated by the software, however, divide the total conditioned floor area used to calculate the duct surface area by two.

Building Science Consortium

## SYSTEM SIZING SPECIFICATION

- 3. One appliance will be equal to 600 Btu/h. Put one appliance in the laundry, and two appliances (1200 Btu/h) in the kitchen. If an auxiliary entertainment area (or equivalent space) exists, then put one appliance there.
  - Use Energy Star appliances and electronics, put less heat back into the space

Building Science Consortium

### SYSTEM SIZING SPECIFICATION

- 4. Gain from people will be set at 300 Btu/h sensible and 300 Btu/h latent, per person.
  - Could be as low as 230 sensible and 200 latent, but not worth arguing over

Building Science Consortium

### SYSTEM SIZING SPECIFICATION

- 5. People will be placed around the house as follows:

#### Basic house

Total people in house = the number of bedrooms plus 1


# bedrooms	Total people	People in master bedroom	People in family and/or living room	People in kitchen
2	3	1	2	0
3	4	1	2	1
4	5	1	2	2

Building Science Consortium

### SYSTEM SIZING SPECIFICATION

- 6a. Infiltration
  - For houses with tested building enclosure leakage below 0.35 cfm50/ft<sup>2</sup> CFA set at 0.2 ach summer and 0.3 ach winter.
  - For houses with tested building enclosure leakage below 0.25 cfm50/ft<sup>2</sup> CFA set at 0.1 ach summer and 0.1 ach winter.
- 6b. Ventilation
  - Set at ASHRAE 62.2 rate both summer and winter.  
 $7.5 (N_{br}+1) + 0.01 (A_{floor})$   
 50 cfm for 2000 ft<sup>2</sup> 3 bedroom house

Building Science Consortium



Building Science Consortium

### SYSTEM SIZING SPECIFICATION

- 7. Glazing U-value and SHGC must be entered according to the NFRC label for the exact glass being installed (get written confirmation from the purchasing manager).

U-value and SHGC of less than 0.35 is good

Interior shading will be selected as:

Drapes-medium, 50% drawn, no insect or external shade screens, ground reflectance equal to 0.20 except ground reflectance equal to 0.32 for glass adjacent to concrete areas such as a patio.

Exception: French doors, entry door side glass, and multi-story open-space windows such as used in foyers (not including transom windows) shall have "None" as internal and external shade. Bathroom windows shall have obscured or block glass.

Building Science Consortium

### SYSTEM SIZING SPECIFICATION

- 8. Outdoor design conditions:
  - Heating: set at the Manual J standard value for the closest climate
  - Cooling: set at the ASHRAE 0.4% design for cooling. Indoor cooling design conditions will be set at 75 F drybulb and 63 F wetbulb (50% RH).

Building Science Consortium

### SYSTEM SPECIFICATION

- 10. The building design cooling load shall be calculated for the worst case elevation option at the solar orientation that produces the highest heat gain.

Building Science Consortium

### COOLING SYSTEM SIZING SPECIFICATION

- 11. Equipment selection, Heating
  - Meet design heating load with no more than 50 F temperature rise (supply air – room air). Good target is 110 to 115 F supply air, or 40 to 45 F temperature rise.

Building Science Consortium

### Heating Temperature Rise

Heating setpoint = 70 F				
Heating HX temp rise (F)	Heating supply air temp (F)	Heating cfm per kW output	Heating cfm per kBtu/h output	Heating cfm per 12 kBtu/h output
14	84	222	65	779
16	86	194	57	692
18	88	172	51	606
20	90	155	45	545
22	92	141	41	496
24	94	129	38	455
26	96	119	35	420
28	98	111	32	390
30	100	103	30	364
32	102	97	28	341
34	104	91	27	321
36	106	86	25	303
38	108	82	24	287
40	110	78	23	273
42	112	74	22	260
44	114	71	21	248
46	116	67	20	237
48	118	65	19	227
50	120	62	18	218
52	122	60	17	210
54	124	57	17	202
56	126	55	16	195
58	128	53	16	188
60	130	52	15	182

! EGUSA uses 360 cfm/12 kBtu/h, this would be for a heat pump

! Modern gas furnace

! Old scorched air furnaces

Building Science Consortium

### Heating Temperature Rise

Heating efficiency = 0.78					
Heating HX temperature rise = 45 F					
Heating system input (kBtu/h)	Heating system output (kBtu/h)	Heating system output (kW)	Heating cfm	Heating cfm/output (cfm/kBtu/h)	Heating cfm/output (cfm/12 kBtu/h)
15	12	3	236	20	242
20	16	5	315	20	242
25	20	6	394	20	242
30	23	7	473	20	242
35	27	8	552	20	242
40	31	9	630	20	242
45	35	10	709	20	242
50	39	11	788	20	242
55	43	13	867	20	242
60	47	14	945	20	242
65	51	15	1024	20	242
70	55	16	1103	20	242
75	59	17	1182	20	242
80	62	18	1261	20	242
85	66	19	1339	20	242
90	70	21	1418	20	242
95	74	22	1497	20	242
100	78	23	1576	20	242
105	82	24	1655	20	242
110	86	25	1733	20	242
115	90	26	1812	20	242
120	94	27	1891	20	242
125	98	29	1970	20	242
130	101	30	2048	20	242

Building Science Consortium

### SYSTEM SIZING SPECIFICATION

- 11. Equipment selection, Cooling
  - Indoor and outdoor coils will be ARI matched
  - The equipment will be selected to meet the design sensible load at the outdoor and indoor design conditions (not ARI standard conditions of 95 outdoor and 80/67 indoor).
    - ARI rating conditions may be very different than actual operating conditions. Extended performance capacity data is important for the designer to properly size the equipment and not resort to common over-sizing habits to compensate for lack of information.
  - Apply 1/2 of the unused latent capacity back to sensible capacity as given by ACCA Manual S.

Building Science Consortium

### SYSTEM SIZING SPECIFICATION

- 11. Equipment selection, Cooling (cont.):
  - If the total load (sensible+latent) exceeds the total capacity of the system by more than 600 Btu/h then go to the next larger size.

Building Science Consortium

**58STA/STX, 4-Way Multipoise Induced Combustion Gas Furnace**  
 Input Capacities: 45,000 thru 155,000 Btuh  
 Product Data

**AIR DELIVERY—CFM (With Filter)\***

UNIT SIZE	RETURN-AIR SUPPLY	SPEED	EXTERNAL STATIC PRESSURE (in. wc)									
			0.1 0.2 0.3 0.4 0.5 0.6 0.7 0.8 0.9 1.0									
			0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0
045-08	Bottom or Side(s)	High	1085	1035	975	915	845	770	675	565	390	195
		Med-High	900	875	830	770	740	640	555	470	360	190
045-12	Bottom or Side(s)	High	1450	1375	1305	1225	1145	1050	955	845	750	510
		Med-High	1360	1300	1240	1175	1115	1040	950	850	755	575
070-08	Bottom or Side(s)	High	2020	1910	1805	1695	1585	1465	1335	1195	1055	825
		Med-High	1835	1745	1660	1565	1465	1345	1215	1085	945	765
070-12	Bottom or Side(s)	High	2425	2295	2180	2065	1950	1820	1685	1545	1405	1105
		Med-High	2240	2135	2035	1930	1820	1690	1555	1420	1280	1005
070-16	Bottom or Side(s)	High	2805	2665	2545	2425	2305	2170	2035	1895	1755	1455
		Med-High	2625	2505	2395	2285	2170	2040	1905	1765	1625	1335
000-14	Bottom or Side(s)	High	3565	3415	3285	3155	3025	2890	2755	2615	2475	2175
		Med-High	3385	3255	3135	3010	2885	2750	2615	2475	2335	2035
000-16	Bottom or Side(s)	High	3950	3795	3665	3535	3405	3265	3125	2985	2845	2545
		Med-High	3775	3635	3515	3390	3265	3130	2995	2855	2715	2415
000-20	Bottom Only	High	4485	4325	4195	4065	3935	3795	3655	3515	3375	3075
		Med-High	4310	4165	4045	3920	3795	3660	3525	3385	3245	2945
000-30	Both Sides or 1 Side & Bottom	High	5245	5085	4955	4825	4695	4555	4415	4275	4135	3835
		Med-High	5070	4925	4805	4680	4555	4420	4285	4145	4005	3705
000-30	1 Side Only	High	4415	4255	4125	3995	3865	3725	3585	3445	3305	3005
		Med-High	4240	4095	3975	3850	3725	3590	3455	3315	3175	2875

Building Science Consortium

**DETAILED COOLING CAPACITIES**

EVAPORATOR AIR	CFM	EWS	CONDENSER ENTERING AIR TEMPERATURE deg F											
			75		85		95		105		115		125	
			Capacity MBtuh†	Total System kW**	Capacity MBtuh†	Total System kW**	Capacity MBtuh†	Total System kW**	Capacity MBtuh†	Total System kW**	Capacity MBtuh†	Total System kW**	Capacity MBtuh†	Total System kW**
24ABA30A30 Outdoor Section With CAP**4221A** Indoor Section														
1050	67	26.87	42.80	25.35	2.35	40.92	21.85	2.67	38.92	20.95	2.94	36.79	20.09	3.29
			39.80	22.27	2.38	37.08	18.52	2.60	35.20	16.74	2.94	32.22	14.90	3.29
			35.34	19.19	2.38	33.74	15.40	2.60	32.07	13.56	2.94	30.52	12.72	3.29
1200	67	34.26	43.06	24.40	2.40	41.67	22.71	2.68	39.58	21.94	2.99	37.30	21.12	3.34
			40.06	20.40	2.43	38.24	19.20	2.63	36.58	17.42	2.99	33.30	15.58	3.34
			35.58	16.97	2.40	34.74	16.23	2.68	33.85	14.42	2.99	32.75	12.59	3.34
1550	67	38.18	43.40	24.40	2.40	41.67	22.71	2.68	39.58	21.94	2.99	37.30	21.12	3.34
			40.06	20.40	2.43	38.24	19.20	2.63	36.58	17.42	2.99	33.30	15.58	3.34
			35.58	16.97	2.40	34.74	16.23	2.68	33.85	14.42	2.99	32.75	12.59	3.34

Multipliers for determining the performance with other indoor sections:

Cooling Indoor Model	Capacity	Power	Furnace Model
CAP**4221A**	1.00	1.00	
CAP**3618A**	0.99	0.98	
CAP**3817A**	0.99	0.99	
CAP**3621A**	0.99	0.99	
CAP**4224A**	1.00	1.00	
CAP**3616A**	0.99	0.99	
CAP**3817A**	0.99	0.99	
CAP**4221A**	1.00	1.00	
CAP**3617A**	0.99	0.99	

Building Science Consortium

Carrier model  
 indoor furnace 58STA070-1216  
 outdoor condenser 24ABA430A300  
 cooling coil CNPHF3017A

**Detailed cooling capacities**

cfm	ews	Sensible cooling capacity (kBtu/h)		Final Sensible Capacity		BSC sens load calc	over/under (kBtu/h) (%)
		at condenser entering temp (F)		apply 0.99 coil correct	adjust from 80 F indoors to 75 F indoors		
		table	design table				
1050	67	26.87	20.74	20.23	20.53	16.56	20.001 -3.44 -17.2
1050	62	24.87	24.73	24.19	20.51	24.49	
1200	67	22.25	22.12	21.61	21.90	18.42	
1200	62	26.73	26.49	25.55	26.23	22.75	

\*Note from Carrier literature:  
 Sensible capacities shown [in Detailed Cooling Capacities] are based on 80\_F (27\_C) entering air at the indoor coil. For sensible capacities at other than 80\_F (27\_C), deduct 835 Btuh (245 kW) per 1000 CFM (480 L/S) of indoor coil air for each degree below 80\_F (27\_C), or add 835 Btuh (245 kW) per 1000 CFM (480 L/S) of indoor coil air per degree above 80\_F (27\_C).

Building Science Consortium

**24ABA4 CHARGING SUBCOOLING (TXV-TYPE EXPANSION DEVICE)**  
 UNIT SIZE---SERIES REQUIRED SUBCOOLING (F)

18---30	10
24---30	11
30---30	8
36---30	10
42---30	12
48---30	9
60---30	9

Building Science Consortium

Table 2: Target Temperature Split (Return Dry-Bulb – Supply Dry-Bulb)

		Return Air Wet-Bulb (°F) (T <sub>return,wb</sub> )																											
		50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	
Return Air Dry-Bulb (°F) (T <sub>return</sub> )	70	20.9	20.7	20.6	20.4	20.1	19.9	19.5	19.1	18.7	18.2	17.7	17.2	16.5	15.9	15.2	14.4	13.7	12.8	11.9	11.0	10.0	9.0	7.9	6.8	5.7	4.5	3.2	
	71	21.4	21.3	21.1	20.9	20.7	20.4	20.1	19.7	19.3	18.8	18.3	17.7	17.1	16.4	15.7	15.0	14.2	13.4	12.5	11.5	10.6	9.5	8.5	7.4	6.2	5.0	3.8	
	72	21.9	21.8	21.7	21.5	21.2	20.9	20.6	20.2	19.8	19.3	18.8	18.2	17.6	17.0	16.3	15.5	14.7	13.9	13.0	12.1	11.1	10.1	9.0	7.9	6.8	5.6	4.3	
	73	22.5	22.4	22.2	22.0	21.8	21.5	21.2	20.8	20.3	19.9	19.4	18.8	18.2	17.5	16.8	16.1	15.3	14.4	13.6	12.6	11.7	10.6	9.6	8.5	7.3	6.1	4.8	
	74	23.0	22.9	22.8	22.6	22.3	22.0	21.7	21.3	20.9	20.4	19.9	19.3	18.7	18.1	17.4	16.6	15.8	15.0	14.1	13.2	12.2	11.2	10.1	9.0	7.8	6.6	5.4	
	75	23.6	23.5	23.3	23.1	22.9	22.6	22.2	21.9	21.4	21.0	20.4	19.9	19.3	18.6	17.9	17.2	16.4	15.5	14.7	13.7	12.7	11.7	10.7	9.5	8.4	7.2	5.9	
	76	24.1	24.0	23.9	23.7	23.4	23.1	22.8	22.4	22.0	21.5	21.0	20.4	19.8	19.2	18.5	17.7	16.9	16.1	15.2	14.3	13.3	12.3	11.2	10.1	8.9	7.7	6.5	
	77	-	24.6	24.4	24.2	24.0	23.7	23.3	22.9	22.5	22.0	21.5	21.0	20.4	19.7	19.0	18.3	17.5	16.6	15.7	14.8	13.8	12.8	11.7	10.6	9.5	8.3	7.0	
	78	-	-	-	24.7	24.5	24.2	23.9	23.5	23.1	22.6	22.1	21.5	20.9	20.2	19.5	18.8	18.0	17.2	16.3	15.4	14.4	13.4	12.3	11.2	10.0	8.8	7.6	
	79	-	-	-	-	-	24.8	24.4	24.0	23.6	23.1	22.5	22.1	21.4	20.8	20.1	19.3	18.5	17.7	16.8	15.9	14.9	13.9	12.8	11.7	10.6	9.4	8.1	
	80	-	-	-	-	-	-	25.0	24.6	24.2	23.7	23.2	22.6	22.0	21.3	20.6	19.9	19.1	18.3	17.4	16.4	15.5	14.4	13.4	12.3	11.1	9.9	8.7	
	81	-	-	-	-	-	-	-	25.1	24.7	24.2	23.7	23.1	22.5	21.9	21.2	20.4	19.6	18.8	17.9	17.0	16.0	15.0	13.9	12.8	11.7	10.4	9.2	
	82	-	-	-	-	-	-	-	-	25.2	24.8	24.2	23.7	23.1	22.4	21.7	21.0	20.2	19.3	18.5	17.5	16.6	15.5	14.5	13.4	12.2	11.0	9.7	
	83	-	-	-	-	-	-	-	-	-	25.3	24.8	24.2	23.6	23.0	22.3	21.5	20.7	19.9	19.0	18.1	17.1	16.1	15.0	13.9	12.7	11.5	10.3	
	84	-	-	-	-	-	-	-	-	-	-	25.0	25.3	24.8	24.2	23.5	22.8	22.1	21.3	20.4	19.5	18.6	17.6	16.6	15.6	14.4	13.3	12.1	10.8

source: California Energy Commission report 2001